

Water Testing Results - **SCESD- Gold Beach**

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
BR #1 Audiology	1949-02-01-XXX-BF-20-A	9/21/2020	11.4
BR #2 Audiology	1949-02-01-XXX-BF-20-A	9/21/2020	8.09
Conference Room	1949-02-01-XXX-KF-20-A	9/21/2020	ND
Office Restroom	1949-02-01-XXX-BF-20-A	9/21/2020	ND

ND = Non Detect - Lead level is below the set detection limits of **15** ppb